



LINN COUNTY PLANNING AND BUILDING DEPARTMENT

Room 114, Linn County Courthouse
PO Box 100, Albany, Oregon 97321
Phone 541-967-3816, Fax 541-926-2060

Basic Design Requirements for Linn County

Soil Bearing Capacity	Assumed 1500 psf maximum without engineered soil bearing analysis
Seismic	D1
Weathering	Moderate
Frost Depth	12"
Ultimate Design Wind Speed	120 mph
Wind Exposure	B
Snow Load	25 psf...If over 700' elevation, call for address specific snow load

Burial Depths

Electrical	Direct burial cable 24" - In PVC conduit 18"
Water	24"
Gas	24"

